



THOR GUARD LIGHTNING PREDICTION & WARNING SYSTEM

SCHOOL/SITE MONTHLY INSPECTION & SENSOR CLEANING LOG

Instructions: School personnel (i.e. administrator, custodian, athletic director, coach) shall inspect the school’s Lighting Prediction & Warning System’s data processing unit for (self-check) pass or fail indication codes (at LED Display Unit), clean the System’s remote sensor unit (outside) and test warning horns/strobes at least once each month. Also, process work order request to the Maintenance Department immediately upon any indications of System failure or any other reliability issues (i.e. remote horn no longer working). Please contact district Env Health & Safety Office (phone: 633-3496 x.4) with any questions, comments, and/or concerns.

Reminder: Unplug power cord at display unit prior to cleaning sensor (as necessary to avoid sounding unit while cleaning it). Remember to plug signal cord and test notification portion of system (horns/strobes) back in after each cleaning. Outside occupants (field/parking lot/grounds) safety are at risk if the system is not working properly, or is working properly but notification system is not plugged in.

School/site Name: _____

YEAR: 20_____	Name of School Employee who Cleaned/tested Unit	Signature of Service Provider	LED Display Unit Shows “PASS” (or “Failure” Code	Horn(s) and Strobe(s) Work when Tested	Comments (including any actions taken to correct known deficiencies)
- date					
January					
February					
March					
April					
May					
June					
July					
August					
September					
October					
November					
December					